



**Gateway Greens South
Surface Water Management
System Facilities Cleaning and Repairs
Specifications & Contract**

ADDENDUM #1

May 14, 2018

This notice is being provided to all prospective bidders to clarify or change information or answer questions submitted for the above bid document.

The following questions/statements were either submitted for written inquiries or asked at the pre-bid meeting held on May 11th, 2018 at 1:30 PM.

QUESTIONS AND ANSWERS

Question 1 If rip-rap is present at the headwalls does the rip-rap need to be removed.

Answer: If rip-rap is inside the headwall it needs to be removed. If there is rip-rap in front of headwall and above the invert, the rip-rap needs to be reset so that it is at the same elevation as the invert.

Question 2 Where can the Morris-Riley Reports be viewed?

Answer: The Morris-Riley reports have been included in the specs.

Question 3 What is the budget or estimated cost for the project?

Answer: The estimated cost for the project is \$337,000

REVISIONS

- Revision 1: Section 3 Measurement and Payment, 3.07 Mobilization / Demobilization and General Requirements have been revised to limit the bid item amounts to 10% of the total bid.**
- Revision 2: Section 4 Technical Specifications, 4.20 Disposal of Waste Material has been revised to indicate the waste stockpile site will be at the Gateway Commons Pool site at the corner of Gateway Blvd and Gateway Lakes Blvd.**
- Revision 3: Section 1 Instructions to Bidders 1.02. Examination of the Site. The due date for questions has been changed from 72hrs before bid due date to 96 Hours.**
- Revision 4: Section 5 Bid Schedule. The Morris-Riley Reports have been included in Section 5.**
- Revision 5: Section 5. The Bid Sheet Support table has been updated to address minor typographical errors.**

Bids will be accepted until 5:00 P.M. Tuesday, May 22nd, 2018. Bids presented after that time will be refused.

BID SHEET SUPPORT

Description	Estimated Quantity	Unit
Fairway Isles		
18" Pipe Sediment and Debris Removal from STR 104-4 to HW 104-4A	30	LF
24" Pipe Sediment and Debris Removal from STR 103-2 to HW 103-1	153	LF
24" Pipe Sediment and Debris Removal from STR WL2-2 to HW WL2-1	183	LF
30" Pipe Sediment and Debris Removal from STR 101-14 to HW 101-13	164	LF
30" Pipe Sediment and Debris Removal from STR 103-8 to HW 103-7	173	LF
30" Pipe Sediment and Debris Removal from STR 104-10 to HW 104-10A	25	LF
30" Pipe Sediment and Debris Removal from STR 101-17 to HW 101-16	193	LF
42" Pipe Sediment and Debris Removal from STR 104-8 to STR 104-10	458	LF
42" Pipe Sediment and Debris Removal from STR 104-8 to HW 104-8A	25	LF
60" Pipe Sediment and Debris Removal from STR 104-2 to HW 104-1	140	LF
60" Pipe Sediment and Debris Removal from STR 101-WL-1 to STR 101-WL-2	114	LF
Hampton Greens		
18" Pipe Sediment and Debris Removal from STR 105-27 to STR 105-28	27	LF
18" Pipe Sediment and Debris Removal from STR 102-5 to STR 102-6	25	LF
60" Pipe Sediment and Debris Removal from STR 105-2 to HW 105-1	152	LF
66" Pipe Sediment and Debris Removal from STR 105-22 to STR 105-21	60	LF
66" Pipe Sediment and Debris Removal from STR 105-22 to STR 105-23	205	LF
Mahogany Run		
24" Pipe Sediment and Debris Removal from STR 109-21 to STR 109-23	245	LF
24" Pipe Sediment and Debris Removal from STR 109-13 to STR 109-19	136	LF
30" Pipe Sediment and Debris Removal from STR 109-14 to STR 109-15	70	LF

30" Pipe Sediment and Debris Removal from STR 109-21 to STR 109-15	105	LF
Sabal Dunes		
15" Pipe Sediment and Debris Removal from STR WL1-2 to STR WL1-3	27	LF
15" Pipe Sediment and Debris Removal from STR 108-7 to STR 108-8	31	LF
15" Pipe Sediment and Debris Removal from STR 108-3 to STR 108-4	29	LF
24" Pipe Sediment and Debris Removal from STR WL1-2 to HW WL1-1	210	LF
24" Pipe Sediment and Debris Removal from STR 108-1 to HW 108-2	175	LF
36" Pipe Sediment and Debris Removal from STR 104-11 to HW 104-11A	40	LF
42" Pipe Sediment and Debris Removal from STR 104-10 to STR 104-11	418	LF
Santa Luz		
15" Pipe Sediment and Debris Removal from STR 101-27 to STR 101-28	88	LF
15" Pipe Sediment and Debris Removal from STR 101-28 to STR 101-29	39	LF
15" Pipe Sediment and Debris Removal from from HW 101-26 to STR 101-27	69	LF
30" Pipe Sediment and Debris Removal from STR WL-14 to HW WL-13	59	LF
30" Pipe Sediment and Debris Removal from STR WL-14 to STR WL-15	96	LF
Summer Wind		
48" Pipe Sediment and Debris Removal from STR 99-04 to HW 100-01	325	LF
48" Pipe Sediment and Debris Removal from STR 99-04 to STR 99-03	230	LF
48" Pipe Sediment and Debris Removal from STR 99-02 to STR 99-03	235	LF
48" Pipe Sediment and Debris Removal from STR 99-02 to HW 99-01	115	LF
Westlinks Dr.		
10" Pipe Sediment and Debris Removal from STR WL-3A1 to STR WL-3C	161	LF
15" Pipe Sediment and Debris Removal from STR 98-S-2 to STR 98-S-1	31	LF

15" Pipe Sediment and Debris Removal from STR WL-11 to STR WL-10	31	LF
15" Pipe Sediment and Debris Removal from STR WL-8 to STR WL-7	30	LF
15" Pipe Sediment and Debris Removal from STR WL-5 to STR WL-4	29	LF
24" Pipe Sediment and Debris Removal from STR 98-S-5 to STR 98-S-4	110	LF
24" Pipe Sediment and Debris Removal from STR 98-S-5 to STR 98-S-7	123	LF
24" Pipe Sediment and Debris Removal from STR 98-S-4 to STR 98-S-3	110	LF
24" Pipe Sediment and Debris Removal from STR 98-S-3 to STR 98-S-2	227	LF
24" Pipe Sediment and Debris Removal from STR WL-5 to STR WL-3A	224	LF
24" Pipe Sediment and Debris Removal from STR WL-3 to STR WL-3A	216	LF
30" Pipe Sediment and Debris Removal from STR 98-S-8 to STR 98-S-7	256	LF
30" Pipe Sediment and Debris Removal from STR WL-5 to STR WL-6	225	LF

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 2/13/13

Video #: 270A

Structure Notes:

Starting Structure #: STR 104-4

Ending Structure #: HW 104-4A

Not on design plans

Pipe Length: 30 LF

Pipe Size: 18" RCP

Notes:

0"-3" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

FIN

Date: 6/14/13

Video #: 436

Structure Notes:

Starting Structure #: STR 103-2
Ending Structure #: *AW* STR 103-1
Pipe Length: 153 LF
Pipe Size: 24" RCP

Notes:

3"-6" Sediment in pipe

BR

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

CR

Date: 12/11/13

Video #: 491

Structure Notes:

Starting Structure #: STR WL2-2

Ending Structure #: ~~STR WL2-1~~

Pipe Length: 183 LF

Pipe Size: 24" RCP

Notes:

0 to 0+75 - 0"-3" Sediment

0+75 to 1+83 - 3"-6" Sediment

Handwritten initials

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

FI

Date: 11/19/13

Video #: 460

Structure Notes:

Starting Structure #: STR 101-14

Ending Structure #: *Handwritten: 11/13* STR 101-13

Pipe Length: 164 LF

Pipe Size: 30" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Handwritten initials

Date: 11/19/13

Video #: 457

Structure Notes:

Starting Structure #: STR 103-8
Ending Structure #: *Handwritten* STR 103-7
Pipe Length: 173 LF
Pipe Size: 30" RCP

Notes:

3"-6" Sediment in pipe

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 2/20/13

Video #: 270B

Structure Notes:

Starting Structure #: STR 104-10

Ending Structure #: HW 104-10A

Pipe Length: 25 LF

Pipe Size: 30" RCP

(42" per design plans)

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

FIB

Date: 11/19/13

Video #: 461

Structure Notes:

Starting Structure #: STR 101-17

Ending Structure #: *mu* STR 101-16

Pipe Length: 193 LF

Pipe Size: 30" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 2/20/13

Video #: 270B

Structure Notes:

Starting Structure #: STR 104-8

Ending Structure #: STR 104-10

Pipe Length: 458 LF

Pipe Size: 42" RCP

Notes:

6"-9" Sediment in pipe

STR 104-9 does not exist

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 2/20/13

Video #: 270A

Structure Notes:

Starting Structure #: STR 104-8

Ending Structure #: HW 104-8A

Pipe Length: 25 LF

Pipe Size: 42" RCP

Notes:

9"-12" Sediment in pipe

Handwritten signature

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Handwritten notes:
5.9.16 / 5.9.16
Lake Interconnect
SDI Cottage LLC 1077
at 104

Date: 2/13/13

Video #: 270A

Structure Notes:

Starting Structure #:	<u>STR 104-2</u>	_____
Ending Structure #:	<u>HW 104-1</u>	_____
Pipe Length:	<u>140 LF</u>	
Pipe Size:	<u>60" RCP</u>	

Notes:

0 to 1+30 - 6"-9" Sediment

1+30 to 1+40 - 24"-30" Sediment

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

[Handwritten signatures and notes]
60" RCP

Date: 3/20/13

Video #: 313

Structure Notes:

Starting Structure #: STR 101-WL-1
Ending Structure #: STR 101-WL-2
Pipe Length: 114 LF (+/-)
Pipe Size: 60" RCP

Notes:

0 to 0+75 - 40"-50" Sediment

0+75 to 0+85 - 50"-60" Sediment

0+90 - 60" Sediment, cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
HAMPTON GREENS

Date: 12/13/13

Video #: 486

Structure Notes:

Starting Structure #: STR 105-27

Ending Structure #: STR 105-28

Pipe Length: 27 LF

Pipe Size: 18" RCP

Notes:

0 to 0+15 - 0"-3" Sediment

0+15 - 3"-6" Sediment (and many leaves), cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
HAMPTON GREENS

Date: 12/13/13

Video #: 487

Structure Notes:

Starting Structure #: STR 102-5

Ending Structure #: STR 102-6

Pipe Length: 25 LF

Pipe Size: 18" RCP

Notes:

0 to 0+13 - 0"-3" Sediment

0+13 - 3"-6" Sediment (and many leaves), cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/13/13

Video #: 282

Structure Notes:

Starting Structure #: STR 105-22

Ending Structure #: STR 105-21

Pipe Length: 60 LF

Pipe Size: 66" RCP

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/13/13

Video #: 282

Structure Notes:

Starting Structure #:	<u>STR 105-22</u>	<u>_____</u>
Ending Structure #:	<u>STR 105-23</u>	<u>18"-24" Sediment at headwall</u>
Pipe Length:	<u>205 LF</u>	
Pipe Size:	<u>66" RCP</u>	

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/18/13

Video #: 286

Structure Notes:

Starting Structure #: STR 109-21

Ending Structure #: STR 109-23

Pipe Length: 245 LF

Pipe Size: 24" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

MS

Date: 3/15/13

Video #: 286

Structure Notes:

Starting Structure #: STR 109-13

Ending Structure #: STR 109-19

Pipe Length: 136 LF

Pipe Size: 24" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB



Date: 3/15/13

Video #: 286

Structure Notes:

Starting Structure #: STR 109-14

Ending Structure #: STR 109-15

Pipe Length: 70 LF

Pipe Size: 30" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/18/13

Video #: 286

Structure Notes:

Starting Structure #:	<u>STR 109-21</u>	<hr/>
Ending Structure #:	<u>STR 109-15</u>	<hr/>
Pipe Length:	<u>105 LF</u>	
Pipe Size:	<u>30" RCP</u>	

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

SR

Date: 12/11/13

Video #: 490

Structure Notes:

Starting Structure #: STR WL1-2

Ending Structure #: STR WL1-3

Pipe Length: 27 LF

Pipe Size: 15" RCP

Notes:

Re-inspection starting from opposite structure

0"-3" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Sgtal Power

Date: 10/8/13

Video #: 455

Structure Notes:

Starting Structure #: STR 108-7

Ending Structure #: STR 108-8

Pipe Length: 31 LF

Pipe Size: 15" RCP

Notes:

0 to 0+03 - 3"-6" Sediment (and many leaves); cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

SR

Date: 10/8/13

Video #: 454

Structure Notes:

Starting Structure #: STR 108-3

Ending Structure #: STR 108-4

Pipe Length: 29 LF

Pipe Size: 15" RCP

Notes:

0 to 0+10 - 0"-3" Sediment in pipe

0+10 to 0+13 - 3"-6" Sediment in pipe; cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

ASD

Date: 6/13/13

Video #: 434

Structure Notes:

Starting Structure #: STR WL1-2

Ending Structure #: *ASD* STR WL1-1

Pipe Length: 210 LF

Pipe Size: 24" RCP

Notes:

3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 2/20/13

Video #: 270B

Structure Notes:

Starting Structure #:	<u>STR 104-11</u>	_____
Ending Structure #:	<u>HW 104-11A</u>	_____
Pipe Length:	<u>40 LF</u>	
Pipe Size:	<u>36" RCP</u>	(42" per design plans)

Notes:

9"-12" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 2/20/13

Video #: 2708

Structure Notes:

Starting Structure #: STR 104-10

Ending Structure #: STR 104-11

Pipe Length: 418 LF

Pipe Size: 42" RCP

Notes:

0 to 1+70 - 6"-9" Sediment

1+70 to 3+18 - 9"-12" Sediment

3+18 to 4+18 - 6"-9" Sediment

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 12/11/13

Video #: N/A

Structure Notes:

Starting Structure #: STR 101-27

Ending Structure #: STR 101-28

Pipe Length: 88 LF

Pipe Size: 15" RCP

Notes:

Unable to locate structures

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 12/11/13

Video #: N/A

Structure Notes:

Starting Structure #: STR 101-28

Ending Structure #: STR 101-29


Pipe Length: 39 LF

Pipe Size: 15" RCP

Notes:

Unable to locate structures

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE



Date: 12/11/13

Video #: N/A

HW
Starting Structure #: STR 101-26
Ending Structure #: STR 101-27
Pipe Length: 69 LF
Pipe Size: 15" RCP

Structure Notes:

Notes:

3"-6" Sediment, cannot enter and proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

*W.L. Dr.
Santa Clara Connection*

Date: 11/27/13

Video #: 465

Structure Notes:

Starting Structure #: STR WL-14

Ending Structure #: *AW* STR WL-13

Pipe Length: 59 LF

Pipe Size: 30" RCP

Notes:

0 to 0+30 - 0"-3" Sediment in pipe

0+30 to 0+59 - 3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

3.4

Date: 11/27/13

Video #: 465

Structure Notes:

Starting Structure #: STR WL-14

Ending Structure #: STR WL-15

Pipe Length: 96 LF

Pipe Size: 30" RCP

Notes:

3"-6" Sediment in pipe

0+08 - 2" Separation at first joint

Paul

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Summer

Date: 3/21/13

Video #: 315

Structure Notes:

Starting Structure #: STR 99-04

Ending Structure #: *MO* STR 100-01

Pipe Length: 325 LF

Pipe Size: 48" RCP

Notes:

12"-15" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/21/13

Video #: 315

Structure Notes:

Starting Structure #: STR 99-04

Ending Structure #: STR 99-03

Pipe Length: 230 LF

Pipe Size: 48" RCP

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Date: 3/21/13

Video #: 315

Structure Notes:

Starting Structure #: STR 99-02

Ending Structure #: STR 99-03

Pipe Length: 235 LF

Pipe Size: 48" RCP

Notes:

0 to 2+10 - 18"-24" Sediment

2+10 to 2+35 - 15"-18" Sediment

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
GATEWAY GOLF & COUNTRY CLUB

Sumner

Date: 3/21/13

Video #: 315

Structure Notes:

Starting Structure #: STR 99-02

Ending Structure #: HW 99-01

Pipe Length: 115 LF

Pipe Size: 48" RCP

12"-15" Sediment at headwall

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS

W. H. P. Co.

Date: 11/26/13

Video #: 482

Structure Notes:

Starting Structure #: STR WL-3A1

Ending Structure #: STR WL-3C

Pipe Length: 161 LF

Pipe Size: 10" DIP

(Not on plans)

Notes:

3"+ Sediment, cannot enter and proceed

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 9/30/13

Video #: 477

Structure Notes:

Starting Structure #:	<u>STR 98-S-2</u>	_____
Ending Structure #:	<u>STR 98-S-1</u>	_____
Pipe Length:	<u>31 LF</u>	
Pipe Size:	<u>15" RCP</u>	

Notes:

3"-6" Sediment in pipe; cannot enter and proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 11/25/13

Video #: 466

Structure Notes:

Starting Structure #: STR WL-11

Ending Structure #: STR WL-10

Pipe Length: 31 LF

Pipe Size: 15" RCP

Notes:

3"-6" Sediment, cannot enter and proceed

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 11/25/13

Video #: 464

Structure Notes:

Starting Structure #: STR WL-8

Ending Structure #: STR WL-7

Pipe Length: 30 LF

Pipe Size: 15" RCP

Notes:

0 to 0+16 - 3"-6" Sediment in pipe; cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 11/27/13

Video #: 464

Structure Notes:

Starting Structure #: STR WL-5

Ending Structure #: STR WL-4

Pipe Length: 29 LF

Pipe Size: 15" RCP

Notes:

0 to 0+14 - 0"-3" Sediment in pipe

0+15 - 3"-6" Sediment in pipe; cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION

WESTLINKS DRIVE

Date: 10/1/13

Video #: 477

Structure Notes:

Starting Structure #:	<u>STR 98-S-5</u>	_____
Ending Structure #:	<u>STR 98-S-4</u>	_____
Pipe Length:	<u>110 LF</u>	
Pipe Size:	<u>24" RCP</u>	(18" RCP per plans)

Notes:

6"-9" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 10/1/13

Video #: 477

Structure Notes:

Starting Structure #: STR 98-S-5

Ending Structure #: STR 98-S-7

Pipe Length: 123 LF

Pipe Size: 24" RCP

Notes:

3"-6" Sediment in pipe

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 9/30/13

Video #: 477

Structure Notes:

Starting Structure #:	<u>STR 98-S-4</u>	_____
Ending Structure #:	<u>STR 98-S-3</u>	_____
Pipe Length:	<u>110 LF</u>	
Pipe Size:	<u>24" RCP</u>	(18" RCP per plans)

Notes:

6"-9" Sediment in pipe

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 9/30/13

Video #: 477

Structure Notes:

Starting Structure #:	<u>STR 98-S-3</u>	_____
Ending Structure #:	<u>STR 98-S-2</u>	_____
Pipe Length:	<u>227 LF</u>	
Pipe Size:	<u>24" RCP</u>	(15" RCP per plans)

Notes:

Re-inspection starting from opposite structure

0 to 0+75 - 6"-9" Sediment

0+75 to 0+85 - 9"-12" Sediment

0+85 - 12"+ Sediment, cannot proceed

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 5/29/13

Video #: 366

Structure Notes:

Starting Structure #:	<u>STR WL-5</u>	<u>_____</u>
Ending Structure #:	<u>STR WL-3A</u>	<u>(Not on plans)</u>
Pipe Length:	<u>224 LF</u>	
Pipe Size:	<u>24" RCP</u>	(18" per design plan)

Notes:

0 to 2+00 - 0"-3" Sediment in pipe

2+00 to 2+24 - 3"-6" Sediment in pipe

GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE

Date: 5/29/13

Video #: 366

Structure Notes:

Starting Structure #:	<u>STR WL-3</u>	<hr/>
Ending Structure #:	<u>STR WL-3A</u>	<u>(Not on plans)</u>
Pipe Length:	<u>216 LF</u>	
Pipe Size:	<u>24" RCP</u>	<u>(18" per design plan)</u>

Notes:

0 to 1+75 - 0"-3" Sediment in pipe

1+75 to 2+00 - 3"-6" Sediment in pipe



GATEWAY SERVICES CDD

STORMWATER SYSTEM INSPECTION

WESTLINKS DRIVE

Date: 10/1/13

Video #: 477

Structure Notes:

Starting Structure #: STR 98-S-8

Ending Structure #: STR 98-S-7

Pipe Length: 256 LF

Pipe Size: 30" RCP

(24" RCP per plans)

Notes:

0 to 1+50 - 6"-9" Sediment

1+50 to 1+75 - 9"-12" Sediment

1+75 to 2+56 - 12"-15" Sediment

**GATEWAY SERVICES CDD
STORMWATER SYSTEM INSPECTION
WESTLINKS DRIVE**

Date: 11/27/13

Video #: 464

Structure Notes:

Starting Structure #:	<u>STR WL-5</u>	_____
Ending Structure #:	<u>STR WL-6</u>	_____
Pipe Length:	<u>225 LF</u>	(266 LF per plan)
Pipe Size:	<u>30" RCP</u>	(24" RCP per plan)

Notes:

3"-6" Sediment in pipe